



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400

Certificate no. : NL13-400-1002-048-11 Revision no.: 6
Description of the product : Lift control unit for electric lifts with monitoring circuit for safety chain, door bridging circuit, detection and activation of unintended movement of the car (UCMP) and brake monitoring (ACOP/UCMP)
Trademark : Arkel
Type no. : ARCODE
Name and address of the manufacturer : ARKEL Elektrik Elektronik San. ve Tic. As.
Eyup Sultan Mah. Sah Cihan Cad. No:69 34885
Sancaktepe – Istanbul / Turkiye
Name and address of the certificate holder : ARKEL Elektrik Elektronik San. ve Tic. As.
Eyup Sultan Mah. Sah Cihan Cad. No:69 34885
Sancaktepe – Istanbul / Turkiye
Certificate issued on the following requirements : Lifts Directive 2014/33/EU
Certificate based on the following standard : EN 81-20:2020 and EN 81-50:2020
(EN 81-1:1998+A3:2009)
Test laboratory : None
Date and number of the laboratory report : None
Date of EU-type examination : 2026-04-17
Additional document with this certificate : Report belonging to the EU-type examination certificate no.: NL13-400-1002-048-11 rev.6
Additional remarks : Key parameters for detecting UCM
Detection distance (variable) : ML magnets switching point
Max. response time DBR board : 10 ms
Speed and distance travelled: to be calculated
Conclusion : The safety component meets the requirements of the Lifts Directive 2014/33/EU considering any additional remarks mentioned above

Amsterdam

Date : 2026-05-08
Valid until : 2031-05-08

Authorised by

W.G. Kasteleijn
Product Manager Certification